


HW-D-0584 SHAFT WALL FLUTED DECK.
 HEAD OF WALL SYSTEM 1, PERPENDICULAR TO SHAFT WALL
 UNDER FLUTED DECK. 1 AND 2 HOUR FIRE RESISTANT ASSEMBLY.
 (SEE UL LISTING FOR WALL FIRE RATING).
 AVAILABLE IN 1 HOUR - SINGLE LAYER OF GYPSUM WALLBOARD



UL-2079 TEST STD